



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Mun of West Elgin (Recreational Water)

Attn : Adam Ecker

22413 Hoskins Line, PO Box 490,, Rodney

, N0L 2C0

Phone: 519-319-1033, Fax:

28-August-2020

Date Rec. : 25 August 2020
LR Report: CA30379-AUG20

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	E.Coli cfu/100mL	Fecal Streptococcus cfu/100mL
1: Analysis Start Date		---	25-Aug-20	25-Aug-20
2: Analysis Start Time		---	15:55	15:55
3: Analysis Completed Date		---	28-Aug-20	28-Aug-20
4: Analysis Completed Time		---	13:14	13:14
5: PWQO Limits		---	100	200
6: Area #1	25-Aug-20 11:00	15.7	8	16
7: Area #2	25-Aug-20 11:00	15.7	8	12
8: Area #3	25-Aug-20 11:00	15.7	10	12
9: Area #4	25-Aug-20 11:00	15.7	< 2	8
10: Area #5	25-Aug-20 11:00	15.7	10	12

PWQO/ I BFR- Provincial Water Quality Objectives and/or International Blue Flag Requirements

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using mFC Basal-BCIG)	ME-CA-[ENV]MIC-LAK-AN-006
cfu/100mL	Fecal Streptococcus by Membrane Filtratio	ME-CA-[ENV]MIC-LAK-AN-008



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

LR Report :

CA30379-AUG20

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*