



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-June-2020

Mun of West Elgin (Recreational Water)

Attn : Jeff Slater

22413 Hoskins Line, PO Box 490,, Rodney
, N0L 2C0
Phone: 519-857-6132, Fax:

Date Rec. : 17 June 2020
LR Report: CA30265-JUN20

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	E.Coli cfu/100mL	Fecal Streptococcus cfu/100mL
1: Analysis Start Date		---	17-Jun-20	17-Jun-20
2: Analysis Start Time		---	13:30	13:30
3: Analysis Completed Date		---	19-Jun-20	19-Jun-20
4: Analysis Completed Time		---	16:12	16:12
5: PWQO Limits		---	100	200
6: Area # 1	17-Jun-20 08:30	16.0	4	2
7: Area # 2	17-Jun-20 08:30	16.0	8	4
8: Area # 3	17-Jun-20 08:30	16.0	60	12
9: Area # 4	17-Jun-20 08:30	16.0	6	< 2
10: Area # 5	17-Jun-20 08:30	16.0	18	8

PWQO/ IBFR- Provincial Water Quality Objectives and/or International Blue Flag Requirements

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using mFC Basal-BCIG)	ME-CA-[ENV]MIC-LAK-AN-006
cfu/100mL	Fecal Streptococcus by Membrane Filtratio	ME-CA-[ENV]MIC-LAK-AN-008